

**BOROUGH OF WANAQUE
CERTIFICATE OF SMOKE ALARM, CARBON MONOXIDE ALARM, AND
PORTABLE FIRE EXTINGUISHER COMPLIANCE**

SMOKE ALARMS: Listed & Tested In Accordance With UL217

- ALL BATTERY OPERATED SMOKE ALARMS MUST HAVE A 10 YEAR SEALED BATTERY. BATTERY OPERATED UNITS THAT HAVE A CHANGEABLE BATTERY ARE NO LONGER PERMITTED AND MUST BE REMOVED WHEN REPLACED.
- SMOKE ALARMS ARE REQUIRED ON EACH LEVEL OF THE HOUSE, INCLUDING THE BASEMENT.
- SMOKE ALARMS ARE NOT REQUIRED IN ATTICS OR CRAWL SPACES.
- SMOKE ALARMS NEED TO BE PLACED WITHIN 10 FEET OF ANY SLEEPING AREA.
- IF YOUR HOUSE HAS HARD WIRED (110 VOLT) SMOKE DETECTORS, THE SYSTEM MUST BE MAINTAINED. THEY ARE PERMITTED TO HAVE CHANGEABLE BATTERIES, BUT IF THE DETECTOR IS OVER 10 YEARS OLD, THEY MUST BE REPLACED PRIOR TO THE INSPECTION.

CARBON MONOXIDE ALARMS: Listed & Tested In Accordance With UL2034

- MUST BE INSTALLED WITHIN 10 FEET OF ANY BEDROOM
- ARE PERMITTED TO BATTERY OPERATED, PLUG IN OR COMBINATION DETECTORS WITH SMOKE ALARMS.

FIRE EXTINGUISHER:

- MUST BE LABELED 2A:10B:C or 3A:40B:C, AND BE LESS THAN 1 YEAR OLD
- MUST BE MOUNTED TO THE WALL, NO HIGHER THAN 5 FEET FROM THE FLOOR, TO THE TOP OF THE HANDLE.
- MUST BE INSTALLED IN A VISIBLE LOCATION, WITHIN 10 FOOT OF THE PATH OF EGRESS OUT OF THE KITCHEN.

THE COST OF THE INSPECTION IS \$200, WHICH CAN BE PAYABLE BY CHECK TO "WANAQUE BOROUGH" OR EXACT CASH.

PAYMENT MUST BE RECEIVED BEFORE INSPECTION DATE!!!!

CALL 973-839-3000 X 7120 TO SCHEDULE AN APPOINTMENT.

INSPECTIONS ARE SCHEDULED FOR MONDAYS BETWEEN 1:00 & 3:00PM AND WEDNESDAYS BETWEEN 7:00 & 9:30AM (NO SET APPOINTMENT TIME MADE)

AFTER INSPECTION IS COMPLETED, INSPECTOR WILL GIVE PERSON AT PROPERTY THE ORIGINAL AND ONLY COPY OF THE CERTIFICATE.