

# Annual Drinking Water Quality Report

## Borough of Wanaque Water Department

For the Year 2012, Results from the Year 2011

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. Our primary water source is wells. Our three wells draw groundwater from an aquifer which is classified as Glacial Stratified Drift. In times of high water demand we purchase water from the North Jersey District Water Supply Commission.

The New Jersey Department of Environmental Protection (NJDEP) has completed Source Water Assessment Reports and Summaries for these public water systems, which are available at [WWW.state.nj.us/dep/swap](http://WWW.state.nj.us/dep/swap) or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding these water systems Source Water Assessments. The Borough of Wanaque's source water susceptibility ratings and a list of potential contaminant sources is attached.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

<b>Wanaque Water Department Test Results</b>						
PWS ID# NJ1613002						
Contaminant	Violati on Y/N	Level Detected	Units of Measure ment	MCL G	MCL	Likely Source of Contamination
<b>Inorganic Contaminants:</b>						
Barium Test results Yr. 2011	N	Range = 0.006 -- 0.016 Highest detect = 0.016	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Test results Yr. 2011	N	Range = 4.0 – 4.4 Highest detect = 4.4	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Test results Yr. 2011 Result at 90 <sup>th</sup> Percentile	N	0.6 2 samples out of 30 exceeded the action level	Ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test results Yr. 2011 Result at 90 <sup>th</sup> Percentile	N	9 1 sample out of 30 exceeded the action level	Ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen) Test results Yr. 2011	N	Range = 0.6 – 3.0 Highest detect = 3.0	Ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Volatile Organic Contaminants / Disinfection Byproducts:</b>						
TTHM Total Trihalomethanes Test results Yr. 2011	N	Range = 9 - 14 Average = 11.	Ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2011	N	Range = ND – 5 Average = 2	Ppb	N/A	60	By-product of drinking water disinfection
<b>Radioactive Contaminants:</b>						
Combined Radium 228 & 226 Test results Yr. 2011	N	1.5	pCi/L	0	5	Erosion of natural deposits
<b>Regulated Disinfectants</b>		<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>
Chlorine		Average = 0.4 ppm		4.0 ppm		4.0 ppm

The Borough of Wanaque Water Department and the North Jersey District Water Supply Commission routinely monitor for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2011. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

North Jersey District Water Supply Commission (NJDWSC)						
PWS ID# NJ1613001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
Turbidity	N	0.44 Highest Measurement  100 % monthly	NTU	0	TT 0.3 NTU % of the NTU	Soil runoff
Total Organic Carbon (%)	N	42.8% Avg. Removal (35% required) (Range 30% - 52%)		NA	TT = % removal	Naturally present in the environment
<b>Inorganic Contaminants:</b>						
Barium	N	0.01	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Nitrate (as Nitrogen)	N	0.3	Ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Volatile Organic Contaminants / Disinfection Byproducts</b>						
THM Total Trihalomethanes	N	Range = 36 - 94 Average = 62	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = 24 - 42 Average = 24	ppb	N/A	60	By-product of drinking water disinfection
<b>Regulated Disinfectants</b>		<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>
Chlorine		Average = 0.9 ppm		4.0 ppm		4.0 ppm

If you have any questions about this report or concerning your drinking water, please call 973 - 839-3000 ext. 7118. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Borough Council meetings.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

## Wanaque Water Department- PWSID # 1613002

Wanaque Water Department is a public community water system consisting of 3 well(s), 0 wells under the influence of surface water, 0 surface water intake(s), 2 purchased ground water source(s), and 1 purchased surface water source(s).

This system's source water comes from the following aquifer(s) and/or surface water body(s) (if applicable): glacial sand and gravel

This system purchases water from the following water system(s) (if applicable): PASSAIC VALLEY WC, POMPTON LAKES MUA/RINGWOOD AVE., RINGWOOD WATER DEPARTMENT

### Susceptibility Ratings for Wanaque Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

**If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radio-nuclides			Radon			Disinfection Byproduct Precursors		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 3		2	1	2	1				3	1		2			3	1	2			3				3
GUDI - 0																								
Surface water intakes - 0																								

- **Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.
- **Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.
- **Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.
- **Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.
- **Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.
- **Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.
- **Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.
- **Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

**DEFINITIONS:**

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Secondary Contaminant- Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) - Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RUL's are recommendations, not mandates.

Total Organic Carbon (TOC) - We are required to remove a certain percentage of (TOC) from our drinking water on a monthly basis. Total Organic Carbon has no adverse health effects. However, TOC provides a medium for the formation of disinfection byproducts.

Turbidity - A measure of the particulate matter or "cloudiness" of the water. High turbidity can hinder the effectiveness of disinfectants.

**Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Wanaque Water Department and the North Jersey District Water Supply Commission are responsible for providing high quality drinking water, but can not control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 second to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

**Cryptosporidium:** is a microbial pathogen found in surface water throughout the United States. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100% removal. The North Jersey Water Supply District Commission's monitoring indicates the presence of these organisms in their source water. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at a greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received monitoring waivers for asbestos and synthetic organic contaminants.

**POSTAL CUSTOMER  
LOCAL**



Borough of Wanaque  
579 Ringwood Avenue  
Wanaque, NJ 07465